


Bioreactor Treatment of Ethers and Alcohols such as MTBE & TBA



Joseph O'Connell, Sc.D., P.E. - Environmental Resolutions, Inc.
Ellen Moyer, Ph.D., P.E. - Greenviroment, LLC
April 2007

Fluidized Bed Bioreactor

- Microorganisms attached to particles degrade contaminants in a water stream
- Ex-situ treatment applicable to GW pump-and-treat operations
- Particles are distributed in the bioreactor by an upflow of the water being treated
- Used in a variety of other applications including wastewater treatment and industrial waste treatment

Oxygen Demand

O₂ is required for biodegradation

Ratio O₂:Contaminants = 3:1

O₂ solubility in water = 9 ppm (eq. with air)

6 ppm O₂ usable - so -


Contaminant bio. limited to 2 ppm in FBR tank unless O₂ is added

HISTORY

- Microbes at JWPCP – Carson, CA - 1997
- Scow Laboratories- UCD isolate PM-1 - 1998
 - CA native
 - Very long doubling time
- UCD – Civil Eng. Pilots 4-inch Trickling Bed Filter - 1998
- ERI installs eight 16-inch TBFs at Healdsburg – using cultures from Davis - 1999
- ERI pilots fluidized bed reactors using cultures from Davis and Healdsburg-1999
 - Six months to populate
- First full-scale fluidized bed - in Palo Alto – 2000
- ~30 other full-scale FBRs to date


Fluidized Bed Operation

- Re-oxygenation by air or O_2 in packed tower
- Recycle dilutes feed
- Recycle rate is fixed @ 50 or 10 gpm to fluidize the bed
- HRT ~ 15 minutes
- Feed – 100,000 ppb-gpm, or 1.3 pounds/day



Bead Filter Operation

- Bead filter handles the solids (Fe, Mn, hardness precipitates)
- Separate recycle loop
- Upflow until solids accumulate
- Isolate bead filter to backwash
- Beat the cake off the beads
- Allow beads to rise
- Filter cake will sink
- Take cake out as slurry
- Put filter back on line
- 1 drum/6 months typical
 - Non-hazardous








FBR Placement in Treatment Train

- **Upstream**
 - Control sources
 - Remove gross free product
 - Remove high BTEX (e.g., by air stripping or GAC)
 - Particulate filter
- **Downstream**
 - Particulate filter to remove bugs
 - GAC
 - Polishing, and to handle upsets
 - Very infrequent carbon changeouts

Palo Alto System Layout



NOTES

- 1) Flow controlled at wells
- 2) Bag filters on well water
- 3) Well water fed directly to process water sump
- 4) Discharge taken directly from clean sump
- 5) Cartridge filters used on BioReactor discharge
- 6) Three carbon canisters on site. But only two in use at any one time.

APPROXIMATE SCALE

0 10 20 30
IN FEET



Palo Alto Fluidized Bed

Date	Flow	MTBE in	MTBE out	TBA in	TBA out	Method
	gpm	ppb	ppb	ppb	ppb	
8/9/00	10	6,200	ND<2.5			
8/11/00	10	7,420	ND<0.5	ND<284	ND<20	(8260)
8/29/00	10	8,000	2,330	Nutrients Needed (N, P, K)		
9/19/00	10	7,600	ND<2.5			
9/22/00	12	13,700	30.6	Reactor Capacity Exceeded O ₂ Booster added		
9/28/00	12	11,100	ND<1	ND<984	ND<3.9	(8260)
10/12/00	14	8,400	3.5			
10/26/00	17	9,670	6.1	ND<980	ND<3.9	
11/9/00	17	12,000	ND<0.5	300	ND<5	Kiff
11/21/00	17	5,300	1.2	120	ND<5	Kiff

Palo Alto Fluidized Bed

Date	Flow	MTBE in	MTBE out	TBA in	TBA out	Method
	gpm	ppb	ppb	ppb	ppb	
11/9/00	17	12,000	ND<0.5	300	ND<5	(8260)
12/20/00	19.5	3,800	0.72	260	ND<5	(8260)
2/14/01	19	7,600	300	O ₂ Booster Re-installed		
8/9/01	19	3,500	ND<2			
10/4/01	15	1,300	ND<2	740	ND<5	(8260B)
11/6/01	14	1,400	ND<2	530	ND<5	(8260B)
12/6/01	17	1,100	ND<2	1100	ND<5	(8260B)
5/8/02	17	710	6	2100	15	(8260B)
9/4/02	17	3,600	1.1	1500	ND<20	
11/6/02	17	900	1	2000	ND<5	
1/03		Found and fixed leaks (holes in vapor recovery system)				

Palo Alto Fluidized Bed

Date	Flow gpm	MTBE in ppb	MTBE out ppb	TBA in ppb	TBA out ppb	Method
1/08/03	11	280	ND<0.5	1,600	ND<5	(8260B)
2/04/03	11	120	ND<0.5	1,100	ND<5	
3/05/03	11	77	ND<0.5	830	ND<5	
4/02/03	12	110	ND<0.5	670	ND<5	
5/08/03	9	49	ND<0.5	570	ND<5	
6/03/03	10	31	ND<0.5	360	ND<20	
7/15/03	12	29	ND<0.5	180	ND<20	
8/06/03	11	23	ND<0.5	150	ND<5	

System shut down and relocated – clean-up sufficient for this site

Bedford, New Hampshire

Challenging System

- Bedrock groundwater
- Weather proof enclosure
- Influent groundwater
 - BTEX (30,000 ppb)
 - MTBE (80,000 ppb)
 - TBA (8,000 ppb)
 - Iron (up to 13 ppm)
 - Manganese (up to 30 ppm)
- Suggest large bioreactor
- System includes:
 - Iron pretreatment
 - Air stripper
 - Small bioreactor
 - 500# carbon polishers
 - Discharge to infiltration gallery i source area



Air Stripper

Stripper – 4 Trays 250-300 cfm
Water to Stripper – up to 5 gpm



BIOREACTOR SYSTEM

- Bio-500 bioreactor – green
- Oxygenation tower - white
- Nutrient feed drum - blue
- Spa heater loop – gray
- Stripper effective for BTEX, MTBE, TAME
- TBA is removed in bioreactor
- Fe comes out in stripper and must be water blasted off
 - Fe pretreatment added 8/06
- Mn comes out in the Bio-500 - much can be siphoned off as a slurry



Carbon Vessels



Bedford NH Data

Date	Flow (gpm)	Temperature (degrees F)	Bioreactor TBA (ug/l)	
			Influent	Effluent
<u>Notes</u>				
2/15/05	1.4	65	6,440	<20
2/22/05	1.5	63	4,930	27
2/28/05	1.4	65	5,820	<20
3/7/05	1.4	80	6,320	<20
3/14/05	0.5	77	3,570	<20
4/5/05	0.9	72	2,770	<20
5/2/05	0.8	67	4,230	<20
6/28/05	1.5	81	1,230	<20
7/19/05	2.0	86	608	<20
7/20/05	1.0	79	574	<20
8/12/05	2.0	76	<20	<20
8/22/05	1.8	73	890	<20
9/20/05	0.9	75	374	<20

Bedford NH Data

Date	Flow (gpm)	Temperature (degrees F)	Bioreactor TBA (ug/l)		Notes
			Influent	Effluent	
10/22/05	1.7	60	3,930	<20	Record rainfall; new well
11/4/05	4.9	54	7,210	4,030	on line; increase loading
11/5/05	4.9	54	4,590	1,820	5-fold; decreased temp.
11/28/05	4.9	56	1,940	540	
12/31/05	2.7	57	490	<20	
1/20/06	3.9	56	1,600	34	
2/13/06	3.3	51	1,480	<20	
3/13/06	4.3	55	245	<20	
4/14/06	4.4	57	276	<20	
5/19/06	2.2	65	70	<20	
6/5/06	4.6	59	185	<20	
6/26/06	5.8	64	912	<20	25% stripper bypass
7/10/06	5.1	64	417	<20	50% stripper bypass
7/21/06	4.5	65	258	<20	75% stripper bypass
8/4/06	4.2	61	<160	<20	100% stripper bypass
9/8/06	4.3	64	NA	<20	100% stripper bypass
10/16/06	4.3	61	<20	<20	100% stripper bypass
10/30/06	4.8	63	277	<20	100% stripper bypass
12/11/06	4.1	59	140	<20	100% stripper bypass
1/29/07	4.9	57	<20	44	100% stripper bypass
3/30/07	3.4	54	<20	<20	0% stripper bypass

Bedford NH – Recent MTBE and BTEX Data

Date	Bioreactor MTBE (ug/l)		Bioreactor BTEX (ug/l)		Notes
	Influent	Effluent	Influent	Effluent	
6/5/06	51	19	ND	ND	0% stripper bypass
6/26/06	530	46	663	ND	25% stripper bypass
7/10/06	>1,900	16	707	ND	50% stripper bypass
7/21/06	2,990	29	579	ND	75% stripper bypass
8/4/06	2,410	42	562	ND	100% stripper bypass
9/8/06	NA	104	NA	ND	100% stripper bypass
10/16/06	1,340	414	922	ND	100% stripper bypass
10/30/06	>1,810	53	4,369	ND	100% stripper bypass
12/11/06	863	453	4,829	ND	100% stripper bypass
1/29/07	562	543	3,912	265	100% stripper bypass
3/30/07	<2	<2	ND	ND	0% stripper bypass

Air stripper was turned back on on 2/12/07 because influent now mostly BTEX:

MTBE 450 ug/l

TBA <1,000 ug/l

BTEX 6,191 ug/l

After 3/30/07, trickle air stripper bypass to feed the bugs in bioreactor

Bedford NH Other Parameters (mg/l)

Date	Stripper Influent	Bioreactor Influent	Bioreactor Effluent
Manganese			
3/14/05	13	12	<1
5/05/05	13	12	6.5
Iron			
3/14/05	13	4	<1
5/05/05	10	5	4
Dissolved Oxygen			
5/05/05		20	5

Bedford NH

- **Bioreactor effectively destroyed TBA to below standard (40 ug/l) except in 11/05 during period of:**
 - Drastically increased TBA mass loading to bioreactor
 - Decreased temperature
 - Malfunctioning iron/manganese pretreatment system
- **Air stripper and GAC were bypassed until recently**
 - Bioreactor can treat ethers, alcohols, aromatics
 - Effluent with oxygen and bugs discharged to groundwater to promote in situ bioremediation
- **Dissolved oxygen concentrations up to 38 mg/l have been achieved by oxygen booster**
- **Water was heated initially but not this past winter**
- **MTBE and TBA concentrations in site GW are down; BTEX contamination remains**
 - Oxygenated effluent is flushing smear zone at source

Maryland Site

- Larger bioreactor (ERI-4000)
- Incoming well water accumulated in frac tanks
- Filtration to remove solids
- Treating BTEX, MTBE, TBA
- Carbon (3 plus spare) for final polish
- Final water accumulated for analysis
- Currently discharge effluent to surface water
- May reinject to groundwater in the future





Maryland Site Startup Data


Sample Date	Flow (gpm)	<u>Benzene (ug/l)</u>		<u>MTBE (ug/l)</u>		<u>TBA (ug/l)</u>	
		in	out	in	out	in	out
8/1/06	4.5	64	0.6	9,450	50	1,290	<25
8/11/06	10.0	4	<1	5,670	1,580	792	<25
8/14/06	10.0	7	<1	9,490	327	522	<25
8/18/06	10.5	5	<1	3,420	4	429	<25
8/29/06	13.0	12	<1	4,790	23	557	<25
9/20/06	13.0	7	<1	3,610	188	431	<25

They stopped analyzing because they accumulate water in frac tank and analyze it prior to discharge - always ND

California Site

- **Maximum groundwater concentrations:**
 - TBA: 80,000 ug/l
 - MTBE: 100 ug/l
 - BTEX: negligible
- **Treated effluent reinjected upgradient of source**
- **Regional Water Quality Control Board:**
 - Limits reinjection to 3 gpm total
 - Requires increased monitoring of downgradient wells
- **Potential concerns to track:**
 - Clogging of reinjection wells
 - Pushing impacted GW off-site
- **As TBA concentrations decrease:**
 - Extraction will ramp up to ~1 gpm/well

California Site Plan and TBA in Groundwater



California Site Startup Data

Date	Flow (gpm)	TBA (ug/l)		MTBE (ug/l)		Notes
		Influent	Effluent	Influent	Effluent	
01/04/07	0.00	<200	<10	3300	<1	
01/10/07	0.00	37000	ND	18	0.21	
01/16/07	0.03	47000	ND<10	38	ND<0.5	
01/23/07	0.06	43000	ND<10	ND<100	ND<1.0	
01/30/07	0.17	15000	ND<10	26	0.52	
02/06/07	0.36	69000	36000	260	88	Lost circ
02/08/07	0.35	91000	920	250	13	Lost circ
02/12/07	0.00	55000	1300	160	15	Lost circ
02/13/07	0.00	NT	NT	NT	NT	
02/20/07	0.29	98000	18	130	3.1	
02/27/07	0.10	58000	ND	140	ND	
03/06/07	0.06	68000	ND	200	0.38	
03/16/07	0.12	43000	ND	150	1.2	

Bioreactor Sizing

Based on loading of VOCs

Standard Size FBR – 5' diameter x 11.5' tall

On 6' x 10' skid

Design loading = 100,000 ppb-gpm

Or with O₂ booster = 250,000 ppb-gpm

Small Size FBR – 2' diameter x 11.5' tall

On 4' x 4' skid

Design loading = 20,000 ppb-gpm

Or with O₂ booster = 40,000 ppb-gpm

Startup

- **Initial startup phase - ERI will:**
 - Add the biomass and start up the bioreactor
 - Operate the bioreactor during initial startup phase
 - Train site personnel on O&M
- **First several months of operation – ERI will:**
 - Review site O&M data
 - Advise on optimizing bioreactor performance

O&M

- **Weekly:**
 - Measure DO, pH, temperature, pressures, flow
 - Gauge depth to sand
 - Backwash bead filter
 - Fill nutrient drum
- **Periodically:**
 - Influent and effluent sampling for VOCs
 - Clean particulate filters
- **Respond if recirculation stops**

ERI-4000 Costs

Capital Costs

- Bioreactor/biomass purchase \$65,000
- Oxygen booster (optional) \$3,500
- Transport/install/startup and GAC/pumps/tanks/piping/elec. site-specific

O&M Costs

- On-site labor 2-3 hr/wk
- Electricity for bioreactor only 1.5 KW
- Materials/chemicals/parts/sludge disposal \$200/month

ERI-500 Costs

Capital Costs

- Bioreactor/biomass purchase \$35,000
- Oxygen booster (optional) \$3,500
- Transport/install/startup and GAC/pumps/tanks/piping/elec. site-specific

O&M Costs

- On-site labor 1.5-2.5 hr/wk
- Electricity for bioreactor only 0.9 KW
- Materials/chemicals/parts/sludge disposal \$100/month

Small BioReactor Huntington Beach

- 2x500 lb Liq. Carbons
- Fluidized Bed Tower
- Clean Water Surge Tank
- Nutrient Feed Drum
- Filters



Comparison with Other Technologies

- AS/SVE slightly effective for MTBE and ineffective for TBA
- MTBE – medium to high concentrations
 - Competitive with GAC
 - Competitive with chemical oxidation
 - Competitive with air stripping w/vapor-phase treatment
 - Not competitive with air stripping w/no vapor-phase treatment
 - Competitive with bioGAC – FBR advantages:
 - Can handle higher concentrations
 - More reliable and controllable
 - Less clogging problems
 - Don't need H_2O_2 – safety issues
- TBA – medium to high concentrations
 - Hard to separate TBA from water
 - Cost-effective technologies limited to biodegradation and chemical oxidation
 - Major advantage over chemical oxidation
 - Hazardous chemicals not used (e.g., H_2O_2 , O_3)

Conclusions

- Contaminant destruction – alcohols, ethers, aromatics
- Low effluent concentrations – can use oxygenated effluent containing bacteria to promote in situ bio
 - Discharge effluent back to groundwater
- Hydraulic control possible
- Good performance at cool temperatures
- Can tolerate high manganese concentrations
- Small volumes of wastes generated
- Bioreactor can be reused at next site